

Fire Lane Markings. Fire lanes shall be designated by painted curbs, signs, stripes, or by a combination of these as approved by the Fire Marshal

- (1) Curbs shall be painted red
- (2) Where curbs are non-existent on a property, a red painted strip, 12-inchesin width, shall be applied to pavement or other hard surface.
- (3) White stenciled lettering 4-inches in height, stating "No Parking Fire Lane" shall be painted on red curbs or red stripes at each end of the fire lane and at intervals of not less than 30-feet through the length of the designated fire lane.
- (4) Where signs are used they shall conform to the following:
 - a. Signs shall be posted at each end of the fire lane at intervals of no more than 40-feet through the length of the designated fire lane.
 - b. Signs shall be of white background with red lettering stating "No Parking Fire Lane". Lettering shall be red in color and no less than two inches in height.
 - c. Sign size shall be not less than 12 x 18 inches and shall be permanently posted above the road or ground surface no less than three feet and no more than eight feet to the bottom of the sign.
 - d. Signs shall be posted so as to be visible from all directions of travel.
- (5) Where both sides of the fire lane is required to be marked, two 6-inch red stripes 20 feet apart and stenciled as per (3) stated above.

(revised 06/05)



Fire Lane Markings The City of Oklahoma City Fire Department





FIRE LANE RED CURBING EXHIBIT 3

All curbing outlining access areas shall be painted red. (See reference below)

White lettering shall be a minimum of 4 inches high, reading FIRE LANE- NO PARKING and shall be placed every 30 feet or portion thereof, on top of designated curbing.

It shall be the responsibility of the property owner(s) to provide, maintain and place NO PARKING signs, markings, striping, white lettering on red painted curbing only in locations where the fire department has designated fire access lanes.

