



Use and Process Specifics

The City of Oklahoma City Fire Department

Group R Occupancies:

Smoke alarms; located in sleeping rooms and outside of sleeping rooms within 21' or manufactures listed requirements, also at the top of stairs and lower level, test with the circuit breaker off.

Access, address, fire extinguishers, private hydrants were verified in worksheet above.

Exit lighting and signage are verified in worksheet items above.

Assembly Use:

Occupant load certificates for assembly rooms are delivered and mounting location instructions are provided, IFC 1004.3.

Access, address, fire extinguishers, private hydrants were verified in worksheet above.

Exit lighting and signage are verified in worksheet above.

Exit door hardware: panic hardware is on all exit doors except main entry, no other security bolt hardware allowed with panic hardware, 1008.1.10.

Decorative materials are fire-resistive in accordance with IFC 803, 804, 806, and 807.

Above-ground Storage Tanks for Flammable and Combustible Liquids:

Use the appropriate worksheet.

Battery Rooms:

Spill control method and materials in place, IFC 608.5 and Table 608.1

Documentation to verify ventilation rate of at least 1 cfm/ft² for floor area, IFC 608.6.

Door signed stating room contains lead-acid batteries, energized electrical circuits, and corrosive liquids, IFC 608.7.

Battery systems are seismically braced and room smoke detection is provided, IFC 608.7 and 608.8.