



Sprinkler- 50% Rough-In Fire Sprinkler Inspection

The City of Oklahoma City Fire Department

To request Temp Power of your building, the General Contractor shall call in the sprinkler permit only. It will start with FIRS-2015-0000. Other permits will be called in when all the work is completed.

- ✓ Consult the approved plans.
- ✓ Verify proper type of piping.
- ✓ Verify backflow device (if installed in building) for size, type, and direction.
- ✓ Confirm the installation of the piping does not have excessive change of directions that are not indicated on approved plans. (Excessive use of extra fittings, such as elbows may effect hydraulic calculations).
- ✓ Proper size of piping.
- ✓ All piping penetrations through fire rated assemblies have been properly sealed by an approved method Proper piping hangers and supports with correct spacing.

