

**AT-0063, Planning and Design of Campus Wide Street and Parking Lot Lighting, Mike  
Monroney Aeronautical Center at Will Rogers World Airport**

**Questions and Answers  
January 27, 2021**

1. Which streets and parking lots are included?

All street and parking lot lighting, campus-wide, are included in this project.

- 1) Will we be tying into an existing lighting control system, or providing a new system?

Scope includes evaluating existing control systems. Our preference is to tie into the ones that are still suitable and in good working order and replace those that are not suitable.

- 2) Will the study include existing light levels or proposed only?

The study only needs to include proposed lighting levels.