

**SC-1078, Sanitary Sewer Rehabilitation, Lighting Creek from SE 15<sup>th</sup> Street to SE 17<sup>th</sup> Street**

**Questions and Answers**

**February 25, 2022**

Is the design for the 72-inch relief line included in the contract or is that a separate project?

**Not included in the contract. It is part of a separate project.**

Is the 72" sewer main referenced in the notice already constructed? **Yes.**

Is the 72" sewer main referenced in the notice in service? **Yes.**

Is the 54" line referenced in the notice in service? **It is a relief line**

What material is the 54" line? **Concrete**

Are there any sewer taps or connections to the 54 inch that haven't been relocated? **No**

After the removal of 240 feet of the 54" line, will OKC require filling the remaining abandoned 54" pipe? **Yes**